

# MarcellusGas.Org

## Document Disclaimer

The information contained in this document represents content obtained from the Pennsylvania Department of Environmental Protection. MarcellusGas.Org makes no claims whatsoever as to the accuracy, timeliness, or completeness of the information provided.

By downloading this document, you agree that you have accepted the terms and conditions set forth in the MarcellusGas.Org User Agreement located at:

[http://www.marcellusgas.org/terms\\_of\\_use.php](http://www.marcellusgas.org/terms_of_use.php)



Pennsylvania Department of Environmental Protection

230 Chestnut Street  
Meadville, PA 16335-3481  
December 24, 2007

Northwest Regional Office

814-332-6860  
Fax: 814-332-6121

[REDACTED]

Re: Act 223, Section 208 Determination  
CID No. 250746  
Oakland Township, Venango County

Dear [REDACTED]

The Department's preliminary investigation has determined that Great Lakes Energy (a.k.a. Range Resources-Appalachia) has affected your water supply during the drilling of their [REDACTED] well.

Based on the letters that the Department received on December 10, 2007, and December 13, 2007, Range Resources has agreed to supply you with sediment filters for the next two months and then re-test your water supply at the end of that two month period. At that time Range Resources has agreed to work with you to do what is needed to get your water supply within suitable drinking water standards. The DEP will continue to monitor your situation until a final resolution is decided upon.

Enclosed are the laboratory results of the sample taken at your residence on November 15, 2007, and a water analysis interpretation fact sheet.

If you have any questions, please contact me at the above listed telephone number.

Sincerely,

Joshua Shaffer  
Water Quality Specialist Trainee  
Oil and Gas Management

Enclosure

cc: J. Lux  
J. Shaffer  
File

JS:sp



Pennsylvania Department of Environmental Protection

230 Chestnut Street  
Meadville, PA 16335-3481  
June 18, 2008

Northwest Regional Office

814-332-6860  
Fax: 814-332-6121

[REDACTED]

Re: Act 223, Section 208 Determination  
CID No. 250746  
Oakland Township, Venango County

Dear [REDACTED]

The Department's investigation has determined that Great Lakes Energy (a.k.a. Range Resources-Appalachia) affected your water supply during the drilling of their [REDACTED] well. Based on the samples taken, on-going correspondence, and the final lab results it is apparent that the water treatment system that was recently installed on your water supply is working correctly. This fulfills Range Resources' obligation in Section 208 of Act 223. At this time, your water supply is within suitable drinking water standards. Enclosed are the laboratory results of the sample taken at your residence on May 27, 2008, and a water analysis interpretation fact sheet.

If you have any questions, please contact me at the above listed telephone number.

Sincerely,

Joshua Shaffer  
Water Quality Specialist Trainee  
Oil and Gas Management

Enclosure

cc: J. Lux  
J. Shaffer  
File

JS:jb